




Safety Message of the Day for IMEA Members



Grounding Secondary Bushings to Prevent Backfeed

Many linemen understand the dangers of energized primaries — but secondary-side hazards often get overlooked. Backfeed from customer-owned generators, solar PV systems, or looped feeders can re-energize secondaries even when utility power is disconnected.

Backfeed = Hidden Energy. Hidden Energy = Danger