IMEA
INDIANA MUNICIPAL ELECTRIC ASSOCIATION
SINCE 1941

Safety Message of the Day for IMEA Members



Clearances – Establish a Safe Work Zone

A properly established clearance is essential to protecting employees working on de-energized distribution circuits. Before beginning work, ensure all identified energy sources have been isolated, required tags and protective measures are in place, and the circuit has been tested for the absence of voltage. Install protective grounds as required by the applicable procedure. Remember, an open switch alone does not guarantee a circuit is safe to work on.

No outage is worth compromising the safety of a lineman.